

WEI

WEST

AH-34

03/09/2011

Temp for scaffold


**INDUSTRIAL
CIRCUIT BREAKER**
Cat. No. TEB132060
60 Amp, 240 VAC 250 VDC
3 Pole, 40°C

Lug Data: 60/75°C Wire
Cat. No: TCAL12
Wire Range: #14 -- #3 CU
 #12 -- #1 AL
Torque: #14 - #1 45 lb-in

*FOR MORE INFO.-SEE GE PUB. GET-2779
*FOR SERIES RATINGS-SEE PUB. GET-006

ON
60
OFF

Interrupting Rating
RMS Sym. Amps, 50/60Hz
Volts kA  
240 10 LISTED
250DC 10 CIR BKR
 2 or 3 Pole Unit
 NACR Type
 Issue NE-635B

GE ED&C Rd 1950
PLAINVILLE, CT 06062, USA




**INDUSTRIAL
CIRCUIT BREAKER**
Cat. No. TEB132060
60 Amp, 240 VAC 250 VDC
3 Pole, 40°C

Lug Data: 60/75°C Wire
Cat. No: TCAL12
Wire Range: #14 -- #3 CU
 #12 -- #1 AL
Torque: #14 - #1 45 lb-in

*FOR MORE INFO.-SEE GE PUB. GET-2779
*FOR SERIES RATINGS-SEE PUB. GET-006

ON
60
OFF

Interrupting Rating
RMS Sym. Amps, 50/60Hz
Volts kA  
240 10 LISTED
250DC 10 CIR BKR
 2 or 3 Pole Unit
 NACR Type
 Issue NE-635B

GE ED&C Rd 1950
PLAINVILLE, CT 06062, USA

